



**ETI Elektroelement d. d.**  
**Obrezija 5**  
**1411 Izlake**  
**SLOVENIA**

Client no.  
122839

Your reference  
Branko Pesan

Our reference  
Christoph Meile

Date  
21.10.2021

## Authorization

Number: **21.0720**  
valid until: **20.10.2024**

Marking:



Based on the documents contained in file **21-BS-0243**, the Federal Inspectorate for Heavy Current Installations grants the firm named above the right to put the equipment listed below on the market marked with the Swiss safety mark in accordance with the NEV.

Equipment: **Residual current circuit-breakers with overcurrent protection (RCBO's)**

Tradename: **ETI**

Type designation **Nominal values**

**KZS-4M** Un: 400/415Vac 50/60Hz  
3L+N, Typ "A"  
In: 6; 10; 13; 16; 20; 25; 32A  
I $\Delta$ n: 0.03; 0.1; 0.3; 0.5A  
Icn: 6kA  
Instantaneous tripping current: B; C

Protection class:

Protection degree: **IP20 (for the front)**

Basis: **CB / DEKRA / NL-59368 / 01.08.2019**





**Authorization**

Number: **21.0720**

CCA / DEKRA / NTR NL--7756 / 01.08.2019  
Test Report / DEKRA / 2235007.50 / 02.07.2019  
EMC TR / SIQ / T251-370/19 / 24.04.2019

Remark:

Test standards: EN 61009-1:12:+A1:14+A2:14+A11:15+A12:16  
EN 61009-2-1:94+A11:98

EN 61543:1995+A11:03+A12:05+A2:06  
EN 55014-1:2006+A1:09+A2:11

Federal Inspectorate for Heavy Current Installations ESTI

Peter Fluri  
Head of Market Surveillance/Safety Mark

