





Test Report issued under the responsibility of:



<b>TEST REPORT</b> <b>IEC 60947-3</b> <b>Low-voltage switchgear and controlgear</b> <b>Part 3: Switches, disconnectors, switch-disconnectors and fuse-combination units</b>	
<b>Report Number</b> .....	2.03.02769.1.0/EFD22/CB
<b>Date of issue</b> .....	15.04.2014
<b>Total number of pages</b> .....	75
<b>CB Testing Laboratory</b> .....	AIT Austrian Institute of Technology GmbH
<b>Address</b> .....	1210 Vienna, Giefinggase 2, AUSTRIA
<b>Applicant's name</b> .....	ETI Elektroelement d.d.
<b>Address</b> .....	1411 Izlake, Obrezija 5, SLOVENIA
<b>Test specification:</b>	
<b>Standard</b> .....	IEC 60947-3:2008 (Third Edition) + A1:2012 in conjunction with IEC 60947-1:2007 (Fifth Edition) + A1:2010
<b>Test procedure</b> .....	CB-Scheme
<b>Non-standard test method</b> .....	N/A
<b>Test Report Form No.</b> .....	IEC60947_3C
<b>Test Report Form(s) Originator</b> ....	OVE
<b>Master TRF</b> .....	Dated 2013-05
<b>Copyright © 2013 Worldwide System for Conformity Testing and Certification of Electrotechnical Equipment and Components (IECEE), Geneva, Switzerland. All rights reserved.</b>	
This publication may be reproduced in whole or in part for non-commercial purposes as long as the IECEE is acknowledged as copyright owner and source of the material. IECEE takes no responsibility for and will not assume liability for damages resulting from the reader's interpretation of the reproduced material due to its placement and context.	
If this Test Report Form is used by non-IECEE members, the IECEE/IEC logo and the reference to the CB Scheme procedure shall be removed.	
<b>This report is not valid as a CB Test Report unless signed by an approved CB Testing Laboratory and appended to a CB Test Certificate issued by an NCB in accordance with IECEE 02.</b>	
<b>Test item description</b> .....	Fuse-switch-disconnectors for cylindrical fuse-links 22x58
<b>Trade Mark</b> .....	ETI
<b>Manufacturer</b> .....	ETI Elektroelement d.d.
<b>Model/Type reference</b> .....	EFD 22
<b>Ratings</b> .....	400V up to 690V / up to 100A (with gG) / 50/60Hz / 1p up to 3p+N 400V up to 690V / up to 100A (with aM) / 50/60Hz / 1p up to 3p+N

<b>Testing procedure and testing location:</b>	
<input checked="" type="checkbox"/> <b>CB/CCA Testing Laboratory:</b>	
Testing location/ address .....	AIT Austrian Institute of Technology GmbH 1210, Vienna, Giefinggase 2, AUSTRIA
<input type="checkbox"/> <b>Associated CB Laboratory:</b>	
Testing location/ address .....	---
Tested by (name + signature) ..:	Ing.J.Ainetter <span style="float: right;"></span>
Approved by (+ signature).....:	Ing.K.Farthofer <span style="float: right;"></span>
<input type="checkbox"/> <b>Testing procedure: TMP</b>	
Tested by (name + signature) ..:	---
Approved by (+ signature).....:	---
Testing location/ address .....	---
<input type="checkbox"/> <b>Testing procedure: WMT</b>	
Tested by (name + signature) ..:	---
Witnessed by (+ signature) .....	---
Approved by (+ signature).....:	---
Testing location/ address .....	---
<input type="checkbox"/> <b>Testing procedure: SMT</b>	
Tested by (name + signature) ..:	---
Approved by (+ signature).....:	---
Supervised by (+ signature).....:	---
Testing location/ address .....	---
<input type="checkbox"/> <b>Testing procedure: RMT</b>	
Tested by (name + signature) ..:	---
Approved by (+ signature).....:	---
Supervised by (+ signature).....:	---
Testing location/ address .....	---



**List of Attachments:**

---

**Summary of testing:****Tests performed:**

A type test was performed according to

- IEC 60947-1:2011 (Edition 5.1)
- IEC 60947-3:2012 (Edition 3.1)

The fuse-switch-disconnectors  
for cylindrical fuse-links 22x58

- EFD 22

have passed the type test successfully.

**Testing location:**


AIT Austrian Institute of Technology GmbH  
Business Unit Electric Energy Systems  
Power Service Center  
Giefinggasse 2  
1210 Vienna  
AUSTRIA

The AIT Austrian Institute of Technology GmbH is a  
recognized CB/CCA Testing Laboratory under the  
responsibility of OVE as the National Certification  
Body.

**Summary of compliance with National Differences:**

---

Copy of marking plate:



**Test item particulars:**

- method of operation ..... : Dependent manual operation
- suitability for isolation ..... : Suitable for isolation
- degree of protection ..... : IP20
- number of poles ..... : 1p, 1p+N, 2p, 3p, 3p+N
- kind of current ..... : AC
- in the case of a.c., number of phases and  
rated frequency ..... : 1 up to 3 / 50/60Hz
- number of positions of the main contacts ..... : 2 (O / I)
- breaking arrangement for fused devices ..... : Double break

**Rated and limiting values, main circuit:**

- rated operational voltage  $U_e$  (V) ..... : 400 up to 690
- rated insulation voltage  $U_i$  (V) ..... : 690
- rated impulse withstand voltage  $U_{imp}$  (kV) ..... : 8
- conventional free air thermal current  $I_{th}$  (A) ..... : 100 (9,5W max. with gG fuse-links)  
100 (7W max. with aM fuse-links)
- conventional enclosed thermal current  $I_{the}$  (A) ..... : -
- rated operational current  $I_e$  (A) ..... : 100 at 400V (gG) | 100 at 500V (gG) | 50 at 690V (gG)  
100 at 400V (aM) | 80 at 500V (aM) | 50 at 690V (aM)
- rated uninterrupted current  $I_u$  (A) ..... : 100 (9,5W max. with gG fuse-links)  
100 (7W max. with aM fuse-links)
- rated frequency (Hz) ..... : 50/60
- utilization category ..... : AC-21B at 690V/100A

**Short-circuit characteristic:**

- rated short-time withstand current  $I_{cw}$  (kA) ..... : 1200A / 1s
- rated short-time making capacity  $I_{cm}$  (kA) ..... : -
- rated conditional short-circuit current ..... : 120kA at 500V (with 100A gG fuse-links)  
120kA at 500V (with 80A aM fuse-links)  
50kA at 400V (with 100A aM fuse-links)

Control circuits ..... : -

Auxiliary circuits ..... : -

Relays and releases ..... : -

**Co-ordination with short-circuit protective devices:**

- kind of protective device ..... : Cylindrical fuse-links 22x58, up to 100A

**Possible test case verdicts:**

- test case does not apply to the test object ..... : N/A
- test object does meet the requirement ..... : P (Pass)
- test object does not meet the requirement ..... : F (Fail)

**Testing:**

Date of receipt of test item ..... : 09/2012, 08/2013 and 02/2014

Date (s) of performance of tests ..... : 09/2012 to 12/2012, 08/2013 and 02/2014

**General remarks:**

The test results presented in this report relate only to the object tested.  
This report shall not be reproduced, except in full, without the written approval of the Issuing testing laboratory.

"(see Enclosure #)" refers to additional information appended to the report.

"(see appended table)" refers to a table appended to the report.

Throughout this report a  comma /  point is used as the decimal separator.

**Manufacturer's Declaration per sub-clause 4.2.5 of IEC60364-552:**

The application for obtaining a CB Test Certificate includes more than one factory location and a declaration from the Manufacturer stating that the sample(s) submitted for evaluation is (are) representative of the products from each factory has been provided .....:  Yes  Not applicable

When differences exist; they shall be identified in the General product information section.

Name and address of factory (ies)..... : ETI Elektroelement d.d.  
Obrezija 5  
1411 Izlake  
SLOVENIA

**General product information:**

Low voltage  
fuse-switch-disconnectors  
for cylindrical fuse-links 22x58

type

**EFD 22**